

INDUSTRIAL HEATER

8400 Wolf Lake Dr., #116, Bartlett, Tennessee 38133
(901) 372-4761 • fax (901)382-4766 • info@iheater.com



**INDUSTRIAL
HEATER**

**AERCO HEATER
HOSPITAL
SIZING WORKSHEET**

DATE _____

ENGINEER _____

PROJECT _____

TYPE OF SERVICE _____

LOCATION _____

CONTACT _____

FIXTURE DATA	NUMBER	VALUE	TOTAL
Autopsy, Sink & Table	_____	2.50	_____
Autopsy, Table	_____	2.00	_____
Bath, Arm	_____	4.00	_____
Bath, Continuous Flow Fill	_____	2.00	_____
Bath, Continuous Flow Operate	_____	1.50	_____
Bath, Emergency	_____	2.00	_____
Bath, Foot	_____	3.00	_____
Bath, Leg	_____	6.00	_____
Bath, Private	_____	1.50	_____
Bath, Sitz	_____	3.50	_____
Bath, Therapeutic	_____	5.00	_____
Bath, Ward	_____	2.00	_____
Hubbard Tank	_____	4.00	_____
Hydrotherapeutic Shower, #1 Head	_____	8.00	_____
Hydrotherapeutic Shower, #2 Spray	_____	12.00	_____
Lavatory, Private	_____	0.75	_____
Lavatory, Public	_____	1.00	_____
Shower, Private *	_____	1.50	_____
Shower, Semi Private *	_____	1.50	_____
Shower, Ward	_____	2.50	_____
Sink, Flushing Rim	_____	2.00	_____
Sink, General Purpose	_____	1.00	_____
Sink, Kitchen, Domestic	_____	3.00	_____
Sink, Laboratory	_____	1.50	_____
Sink, Pantry	_____	2.50	_____
Sink, Scrub-up	_____	1.50	_____
Sink, Slop	_____	2.50	_____
Miscellaneous	_____	_____	_____
Miscellaneous	_____	_____	_____
Miscellaneous	_____	_____	_____
Miscellaneous	_____	_____	_____
Miscellaneous	_____	_____	_____
Miscellaneous	_____	_____	_____
TOTAL	_____	_____	_____

* Based on 3 GPM

Total Fixture Units _____
 Inlet Water Temperature _____
 Outlet Water Temperature _____
 Required GPM _____
 Steam Pressure to Valve _____
 Steam Pressure to Coils _____
 Steam Demand (#/hr) _____

NOTES

