



**UNDERWRITERS LABORATORIES INC.**

333 PFINGSTEN ROAD • NORTHBROOK, ILLINOIS 60062-2096

April 25, 1988

Aerco International, Inc.  
Mr. Kenneth W. Cohen  
159 Paris Avenue  
Northvale, NJ 07647

Our Reference: MH14496

Subject: Thermal Efficiency Testing

Dear Mr. Cohen:

This will report the results of thermal efficiency testing of Model KC-1000M condensing gas-fired water heater conducted at your factory and witnessed by the writer during the week of March 14, 1988.

The thermal efficiency test was conducted- following the guidelines in Part II, Par. 2.8, Addenda Pages 6, 7, and 8, ANSI Z21.10.3B-1986. Results of tests at rated input and at a turndown ratio of 10:1 indicate thermal efficiencies in excess of 93 percent and 99 percent, respectively.

If you have any comments or questions, please do not hesitate to contact the undersigned.

Very truly yours,

T. K. THOMPSON (Ext. 3270)  
Engineering Associate  
Heating, Air Conditioning and  
Refrigeration Department

Reviewed by:

J. HUGHES (Ext. 2472)  
Engineering Group Leader  
Heating, Air Conditioning and  
Refrigeration Department

TKT: jwb  
L2

Look For The  Listing or Classification Mark On The Product